

STRADA HYBRID ■ CORRECTION FACTORS

AVERAGE CORRECTION FACTORS

ACCORDING TO EN16430 - 75/65/20°C

Tv	Tl	Tr	25	30	35	40	45	50	55	60	65	70	75	80	85
90	18		0.53	0.64	0.74	0.83	0.91	0.99	1.06	1.13	1.19	1.27	1.32	1.38	1.44
	20		0.46	0.59	0.69	0.78	0.86	0.94	1.01	1.08	1.15	1.22	1.28	1.33	1.39
	22		0.38	0.53	0.64	0.73	0.81	0.89	0.97	1.03	1.10	1.18	1.23	1.29	1.35
	24		0.28	0.47	0.58	0.68	0.77	0.85	0.92	0.99	1.06	1.12	1.19	1.24	1.30
85	18		0.50	0.61	0.71	0.79	0.87	0.94	1.01	1.08	1.16	1.21	1.27	1.32	
	20		0.43	0.56	0.66	0.74	0.82	0.90	0.97	1.03	1.10	1.17	1.22	1.28	
	22		0.36	0.50	0.61	0.70	0.78	0.85	0.92	0.99	1.05	1.12	1.18	1.23	
	24		0.26	0.44	0.55	0.65	0.73	0.80	0.88	0.94	1.01	1.08	1.13	1.19	
80	18		0.47	0.58	0.67	0.75	0.83	0.90	0.97	1.03	1.10	1.16	1.21		
	20		0.41	0.53	0.62	0.71	0.78	0.85	0.92	0.99	1.06	1.11	1.17		
	22		0.34	0.47	0.57	0.66	0.74	0.81	0.88	0.94	1.01	1.07	1.12		
	24		0.24	0.41	0.52	0.61	0.69	0.76	0.83	0.90	0.97	1.02	1.08		
75	18		0.44	0.55	0.63	0.71	0.79	0.85	0.92	0.99	1.04	1.10			
	20		0.38	0.50	0.59	0.67	0.74	0.81	0.87	0.95	1.00	1.06			
	22		0.31	0.44	0.54	0.62	0.70	0.76	0.83	0.90	0.96	1.01			
	24		0.22	0.39	0.49	0.57	0.65	0.72	0.79	0.86	0.91	0.97			
70	18		0.41	0.51	0.60	0.67	0.74	0.81	0.88	0.93	0.99				
	20		0.36	0.46	0.55	0.63	0.70	0.76	0.84	0.89	0.95				
	22		0.29	0.41	0.50	0.58	0.65	0.72	0.78	0.85	0.90				
	24		0.20	0.36	0.46	0.54	0.61	0.68	0.74	0.80	0.86				
65	18		0.39	0.48	0.56	0.63	0.70	0.76	0.83	0.88					
	20		0.33	0.43	0.51	0.59	0.65	0.72	0.78	0.84					
	22		0.27	0.38	0.47	0.54	0.61	0.67	0.74	0.79					
	24		0.18	0.33	0.42	0.50	0.57	0.63	0.70	0.75					
60	18		0.36	0.44	0.52	0.59	0.65	0.72	0.77						
	20		0.30	0.40	0.48	0.55	0.61	0.68	0.73						
	22		0.24	0.35	0.43	0.50	0.57	0.63	0.69						
	24		0.17	0.30	0.39	0.46	0.52	0.59	0.64						
55	18		0.33	0.41	0.48	0.55	0.61	0.66							
	20		0.27	0.36	0.44	0.50	0.57	0.62							
	22		0.22	0.32	0.39	0.46	0.52	0.58							
	24		0.15	0.27	0.35	0.42	0.48	0.54							
50	18		0.29	0.37	0.44	0.50	0.56								
	20		0.25	0.33	0.40	0.46	0.52								
	22		0.19	0.28	0.36	0.42	0.48								
	24		0.13	0.24	0.31	0.38	0.44								
45	18		0.26	0.33	0.40	0.46									
	20		0.22	0.29	0.36	0.42									
	22		0.17	0.25	0.32	0.38									
	24		0.11	0.21	0.28	0.33									
40	18		0.23	0.30	0.35										
	20		0.19	0.25	0.32										
	22		0.14	0.21	0.28										
	24		0.09	0.17	0.23										
35	18		0.19	0.26											
	20		0.15	0.21											
	22		0.11	0.18											
	24		0.07	0.14											
30	18		0.16												
	20		0.12												
	22		0.08												
	24		0.04												

The indicated outputs with ΔT 50 are the exact outputs, measured in accordance with EN16430. An average correction factor is given in this table for all other ΔT outputs, applicable for all dimensions. These correction factors are to be used for guidance only.